

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1591:218 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-427 Fax (941) 739-4334

DESIGN: Models "G1-VM, G1R-VM, G1F-VM and G1RF-VM synchronizable strobe light, followed by -R, F or none, followed by -VM, followed by -15, -30, -75, or -110. The suffix R refers to red rather than white housing and the suffix F refers to the word "FIRE" refers to a silk-screened word "FIRE" on the strobe housing. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 24-30 VDC
Candela: 15cd, 30cd, 60cd, 75cd, 110cd Selectable

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. Units are synchronizable when used with Models G1M or G1M-RM sync module (CSFM Listing No. 7300-1591:201) which may employ Models SIGA-CC1S or SIGA-MCC1S Auto-Sync output modules as an accessory (CSFM Listing No. 7300-1591:121). For indoor use and wall mount only.

07-29-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 29, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**